

REVISED TENDER PAPER

SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF 1.5 TON SPLIT AIR-CONDITIONERS (5 STAR) WITH STABILIZERS Tender Reference No. : Labour/2016-17/01 Date: 25.07.2016

Sl. No.	RFP Reference			Existing Clause	Modified as
	Clause No.	Page No.	Clause Details		
1.	5 of B	5	Eligibility Criteria	The bidder shall furnish the information on all past supplies and satisfactory performance for 1 and 2 above in the Proforma under Annexure III .	The bidder shall furnish the information on all past supplies in preceding 3 years i.e. 2013-14, 2014-15 & 2015-16 and satisfactory performance in the Proforma under Annexure III . From amongst the supplies during this period, atleast 2 no.s (two) of supplies must be to the Government / Semi-Government / PSUs.
2.	17.3	28	Warranty	The minimum warranty period shall be 1 year.	The minimum warranty period of AC and the Stabiliser should be for 1 year. However, the warranty of the compressor of AC should be at least 5 years.
3.	ANNEXURE VI (Serial No. 1(a))	43	Price Schedule	Supply, delivery and installation of 1.5 TR split wall mounted cordless remote Air conditioners of 5 star rating with independent copper coil evaporator 1.5 TR each and one compressor of 1.5 TR each. Nominal cooling capacity 4500 kcal/Hr. (suitable for operation on single phase 230 volts, 15Hz, Ac supply), Min. Room Air Flow (cub. m/h):700 at locations as per the list attached.	Supply, delivery and installation of 1.5 TR split wall mounted cordless remote Air conditioners of 5 star rating with independent copper coil evaporator 1.5 TR each one compressor and condenser unit of 1.5 TR each. Nominal cooling capacity 4500 kcal/Hr (suitable for operation on single phase 230 volts, 15Hz, AC supply), Min. Room Air Flow (cub. m/h):700 at locations as per the list attached.
4.	ANNEXURE VI (Serial No. 2)	43	Price Schedule	Supply of 4 KVA stabilizers for 1.5 TR AC unit of a standard make with suitable wall mount option as per site requirement.	Supply of 5 KVA stabilizers with input voltage range 90V-280V for 1.5 TR AC unit of a standard make with suitable wall mount option as per site requirement.

Bidder has to sign and submit the corrigendum along with tender document during submission of bid.

Other terms and conditions of the tender along with Payment Terms remain unchanged.